OpsAuditHub opsaudithub.com	DOC ID: **SAF-0264**	REVISION: **Rev 2.4 (2026)**
	STANDARD: **OSHA 29 CFR 1910.22 (Walking-Working Surfaces) & NFPA 101 (Life Safety Code)**	AUDIT FREQUENCY: **Daily Pre-Shift**

Hotel Guest Slip Trip Hazard Assessment Inspection Checklist

Operational Scope: Establishes a systematic daily protocol for identifying, evaluating, and mitigating slip, trip, and fall hazards across all guest-accessible areas of the hotel property. Ensures immediate corrective actions are taken to maintain compliance with federal safety regulations and protect hotel patrons and staff from injury.

MANDATORY PPE:	Slip-Resistant Footwear (ASTM F2913), High-Visibility Safety Vest, Nitrile Chemical-Resistant Gloves, LED Safety Flashlight / Lumens Meter, Wet Floor Caution Signage Kit
PREREQUISITES:	Review previous shift incident logs and guest complaints regarding floor or pathway conditions. | Ensure all inspection tools, including slip-resistance meters and lighting meters, are calibrated and operational. | Notify department supervisors of inspection routes to coordinate access to high-traffic public areas.

LOBBY, CORRIDORS, AND PUBLIC WALKWAYS

#	COMPONENT / ITEM	VERIFICATION CRITERIA & ACCEPTANCE STANDARD	SEVERITY	STATUS
1	**Flooring Material & Transitions**	All tile, carpet, and wood flooring transitions must be flush, with no fraying edges, curled carpet seams, or elevation changes exceeding 0.25 inches without a tapered bevel.	**Critical (Immediate Out of Service)**	**[ ] PASS [ ] FAIL [ ] N/A**
2	**Entrance Mats & Rug Anchoring**	All entryway mats and area rugs must feature high-friction, non-skid backing and lie completely flat without bunching, ripples, or sliding under foot traffic.	**Warning**	**[ ] PASS [ ] FAIL [ ] N/A**
3	**Corridor Illumination Levels**	Light fixtures along all guest hallways and emergency exit paths must maintain a minimum of 1.0 foot-candle at floor level with no burned-out bulbs or flickering fixtures.	**Warning**	**[ ] PASS [ ] FAIL [ ] N/A**
4	**Obstruction-Free Egress Routes**	Hallways and public thoroughfares must remain entirely clear of housekeeping carts, luggage trolleys, room service trays, and maintenance equipment.	**Critical (Immediate Out of Service)**	**[ ] PASS [ ] FAIL [ ] N/A**

POOLSIDE, SPA, AND EXTERIOR WALKWAYS

#	COMPONENT / ITEM	VERIFICATION CRITERIA & ACCEPTANCE STANDARD	SEVERITY	STATUS
5	**Pool Deck Drainage & Puddling**	Pool and spa surrounding decks must exhibit proper slope toward drains with no standing water or localized puddling exceeding 0.125 inches in depth.	**Critical (Immediate Out of Service)**	**[ ] PASS [ ] FAIL [ ] N/A**
6	**Exterior Walkway Weather Hazards**	Exterior pathways, stairs, and portico entries must be free of accumulated ice, standing rainwater, fallen leaves, or loose gravel hazards.	**Critical (Immediate Out of Service)**	**[ ] PASS [ ] FAIL [ ] N/A**
7	**Handrails and Stair Treads**	Stairwell handrails must be firmly secured without looseness, and outdoor stairs must feature intact anti-slip nosing treads on every step edge.	**Critical (Immediate Out of Service)**	**[ ] PASS [ ] FAIL [ ] N/A**

DINING, RESTROOMS, AND BACK-OF-HOUSE INTERFACES

#	COMPONENT / ITEM	VERIFICATION CRITERIA & ACCEPTANCE STANDARD	SEVERITY	STATUS
8	**Restroom Floor Conditions**	Public restrooms must be dry, free from chemical residue, and equipped with functioning automatic exhaust fans to prevent moisture condensation buildup on tile floors.	**Warning**	**[ ] PASS [ ] FAIL [ ] N/A**
9	**Spill Station Readiness**	Spill cleanup stations (absorbent powder, caution cones, paper towels) located near restaurants and bars must be fully stocked and easily accessible.	**Standard**	**[ ] PASS [ ] FAIL [ ] N/A**

Certified Inspector / Lead Operations Auditor Signature: _____	**Date / Time:** _____	**Badge / Cert #:** _____
Site Safety Supervisor / General Manager Sign-off: _____	**Review Date:** _____	**Audit Status:** [ ] Approved [ ] Rectify

COMPLIANCE NOTICE: This document must be archived for a minimum of 12 months in accordance with workplace safety recordkeeping guidelines and insurance verification standards.

DIGITAL INSPECTION UPGRADE: Run this audit on mobile/tablet, attach photos & automate compliance records. **Start Free Mobile Audit →**