OpsAuditHub opsauditihub.com	DOC ID: **SAF-0051**	REVISION: **Rev 2.4 (2026)**
	STANDARD: **OSHA 29 CFR 1926.502 / 1926.503**	AUDIT FREQUENCY: **Daily Pre-Shift**

Jobsite Fall Protection Daily Log Sheet

Operational Scope: Establishes a mandatory daily pre-shift verification protocol to inspect personal fall arrest systems and active work zones. Ensures proactive hazard mitigation and compliance with federal construction safety standards before elevated work begins.

MANDATORY PPE:	Full-Body Harness (ANSI Z359.11), Shock-Absorbing Lanyard or Self-Retracting Lifeline (SRL), Hard Hat with Chin Strap (ANSI Z89.1), Slip-Resistant Steel-Toe Boots (ASTM F2413), High-Visibility Class 2 Safety Vest, Heavy-Duty Rigging Gloves
PREREQUISITES:	Review site-specific Fall Protection Plan and rescue procedures prior to shift startup. | Verify weather conditions are favorable for elevated operations (wind speeds under 30 mph, no active lightning).

PERSONAL FALL ARREST SYSTEMS (PFAS) INSPECTION

#	COMPONENT / ITEM	VERIFICATION CRITERIA & ACCEPTANCE STANDARD	SEVERITY	STATUS
1	**Full-Body Harness Webbing**	Inspect for cuts, fraying, chemical burns, or excessive fiber wear. Stitching must be intact with no pulled threads.	**Critical (Immediate Out of Service)**	[ ] PASS [ ] FAIL [ ] N/A
2	**Harness D-Rings and Buckles**	Check dorsal, side, and sternal D-rings for distortion, cracks, or sharp edges. Tongue buckles must engage securely.	**Critical (Immediate Out of Service)**	[ ] PASS [ ] FAIL [ ] N/A
3	**Connecting Devices (Lanyards & SRLs)**	Inspect snap hooks and carabiners for self-closing/locking gate operation and corrosion. Check lifeline cable or webbing for kinks and cuts.	**Critical (Immediate Out of Service)**	[ ] PASS [ ] FAIL [ ] N/A
4	**Shock Absorber Packs**	Verify deployment cover is intact and unruptured, indicating no prior fall impact or excessive stress loading.	**Critical (Immediate Out of Service)**	[ ] PASS [ ] FAIL [ ] N/A

JOBSITE ANCHOR POINTS & WALKING-WORKING SURFACES

#	COMPONENT / ITEM	VERIFICATION CRITERIA & ACCEPTANCE STANDARD	SEVERITY	STATUS
5	**Anchor Points and Tie-Off Connectors**	Verify anchor point is certified by a competent person capable of supporting at least 5,000 lbs per worker attached, or engineered drop lines.	**Critical (Immediate Out of Service)**	[ ] PASS [ ] FAIL [ ] N/A
6	**Floor Openings and Roof Edges**	Ensure all floor holes, skylights, and unprotected roof edges are securely covered, barricaded, or guarded with compliant standard railings.	**Critical (Immediate Out of Service)**	[ ] PASS [ ] FAIL [ ] N/A
7	**Scaffolding and Work Platforms**	Check scaffold planks for full decking, secure tie-offs, toe boards, and proper guardrail systems without missing components.	**Warning**	[ ] PASS [ ] FAIL [ ] N/A

WARNING LINES, BARRICADES & RESCUE READINESS

#	COMPONENT / ITEM	VERIFICATION CRITERIA & ACCEPTANCE STANDARD	SEVERITY	STATUS
8	**Controlled Access Zones & Warning Lines**	Warning lines must be rigged at least 6 feet from the unprotected edge and flagged with high-visibility material every 6 feet.	**Warning**	[ ] PASS [ ] FAIL [ ] N/A
9	**Rescue Equipment & Communication**	Confirm designated rescue personnel are on site, communication radios are fully charged, and rescue plan is accessible.	**Critical (Immediate Out of Service)**	[ ] PASS [ ] FAIL [ ] N/A
10	**Debris Netting and Catch Platforms**	Inspect safety nets and drop protection zones below work areas for structural integrity and accumulated debris.	**Standard**	[ ] PASS [ ] FAIL [ ] N/A

Certified Inspector / Competent Person Signature: _____	**Date / Time:** _____	**Badge / Cert #:** _____
Site Safety Supervisor / Operations Manager Sign-off: _____	**Review Date:** _____	**Audit Status:** [ ] Approved [ ] Rectify

COMPLIANCE NOTICE: This document must be archived for a minimum of 12 months in accordance with workplace safety recordkeeping guidelines.